

## Dan Heil

---

**From:** John Audy <JAudy@winooski.vt.gov>  
**Sent:** Thursday, November 21, 2019 10:52 AM  
**To:** David Burke; Liam Keating  
**Cc:** Dan Heil; Darcy Handy <darcyhandy@hotmail.com> (darcyhandy@hotmail.com)  
**Subject:** RE: 2016-98: Winooski

Dave,

This meets the access requirements and as AHJ we would accept this. I do not see that a hydrant has been drawn.... That is something we have requested through the many versions of this we have seen.

Thanks



**John Audy**  
Fire Chief  
winooski.vt.gov • 802 373 7891

---

**From:** David Burke <dwburke@olearyburke.com>  
**Sent:** Thursday, November 14, 2019 4:21 PM  
**To:** John Audy <JAudy@winooski.vt.gov>  
**Cc:** Dan Heil <dheil@olearyburke.com>; Darcy Handy <darcyhandy@hotmail.com> (darcyhandy@hotmail.com) <darcyhandy@hotmail.com>  
**Subject:** 2016-98: Winooski

John: As a follow-up to your request of a turn-around per NFPA to serve the Lafountain Road Project we are proposing a conforming turn-around which will first require a Boundary Line Adjustment with the parcel to the South.

We trust the attached is satisfactory to you and are seeking your e-mail confirmation prior to proceeding with the necessary Boundary Line Adjustment to allow for a conforming "T" type turn-around with 30' radii and appropriate lengths. If you have any questions, I can be reached at 878-9990. Thank you.

David W. Burke  
O'Leary-Burke Civil Associates, PLC.